

## NLC India Limited OFFICE OF THE CHIEF GENERAL MANAGER/TA



## SANITARY CERTIFICATE

SCHOOL (CBSE), BLOCK-17, NEYVELI - 607801 on 24.11.2022 and found that each of the served classes are sufficient for the maximum number of pupils taught therein and is properly ventilated and lighted, that the building is maintained in substantial repairs, and that it is neat and clean. The latrine arrangements are adequate and satisfactory, that the supply of drinking water is protected wholesome and that in all other necessary aspects the sanitation is SATISFACTORY.

## Subject to condition:

- 1. The toilet and Urinals should be disinfected thrice a day (Fore Noon two times & After Noon 1 time)
- 2. All kind of one time use Plastics are banned in Neyveli-TS. No plastic should be used in the school premises.(Plastic carry bags, Plastic covers & cups, etc. irrespective of its microns)
- 3. No sale of tobacco within the radius of 100 meters of the educational institution (Head Master/Principal should ensure).
- 4. As per school health norms not more than 40 students are permitted/class and area required is 400 Sq.Ft. This may be adhered to. In view of covid situation, Covid guidelines may be followed strictly as issued by Govt. from time to time.
  - At Sindhu Building
    - Damaged toilet pans at Girls and Boys toilet should be replaced.
  - > At Brahmaputra Building,
    - Tap water connection to be provided to Boys Toilet.
    - Damaged urinals should be replaced.
    - Damaged toilet doors should be repaired/replaced.
  - At Ganga Building,
    - Tap water connection to be provided to Boys Toilet.
    - Damaged toilet doors should be repaired/replaced.
    - Damaged toilets pans should be replaced.
  - Every class room should be provided with sufficient lighting.
  - White washing should be carried out for the academic year 2023-24

Date No.:...04/02/2023
Station: Neyveli

Asst. Sanitary Officer/H&S
NLC India Limited Neyveli
Asst. Manager
(Asst. Sanitary Officer)
Health & Sanitation
Township Administration
NLC India Ltd., Nevveli-607801